## Circuit Breaker for Equipment thermal, Threaded neck type, Reset type, Quick connect terminals



#### Description

- Threaded neck type 6 mm
- Thermal circuit breaker
- 1-pole
- Reset type
- Quick connect terminals 6.3 x 0.8 mm

### **Unique Selling Proposition**

- Compact design
- Positively trip-free release
- Available with cover
- Different mounting possibilities

## **Technical Data**

Rated Voltage AC	240 V: 50/60 Hz
Rated Voltage DC	48 V
Rated current range AC	0.05 - 16 A
Conditional short circuit ca-	IEC: Inc, PC1, AC 240 V: 2 kA
pacity	
Short circuit capacity Icn	at ln < 6.5 A/240 VAC : 8 x ln
	at In ≥ 6.5 A/240 VAC : 96 A
Degree of Protection	from front side IP 40 acc. to IEC 60529
Dielectric Strength	50Hz: > 1.5 kV
	Impulse 1.2/50
Insulation Resistance	$500 \text{ VDC} > 100 \text{ M}\Omega$
Endurance typical	2 x lr: 500 switching cycles
Endurance minimum	Reset type
	AC : 2 x lr , cos φ 0.6 :
	DC : 2 x lr , L/R = 2 - 3 ms :
	50 switching cycles

	@ 6 x lr, cos φ 0.6
	UL / CSA: min. 50trips
	@ 1.5 x lr, cos φ 0.75
Allowable Operation Temp.	-5 °C to 60 °C
/ibration Resistance	± 1.5 mm @ 10 - 60 Hz
	acc. to IEC 60068-2-6, test Fc
	5 G @ 60 - 500 Hz
	acc. to IEC 60068-2-6, test Fc
Shock Resistance	100 G / 6ms
	acc. to IEC 60068-2-27, test Ea
Tripping Type	Thermal
Actuation Type	Reset type
Veight	ca. 10g

pdf datasheet, html-datasheet, General Product Information, Distributor-

IEC: min. 40 trips

Stock-Check, Detailed request for product, Product News

#### **Approvals and Compliances**

Detailed information on product approvals, code requirements, usage instructions and detailed test conditions can be looked up in Details about Approvals

See below:

Weblinks

Overload

Applications - Power tools

- Household Equipment

- Industrial appliances

**Approvals and Compliances** 

- Power supplies and chargers

#### Approvals

The approval mark is used by the testing authorities to certify compliance with the safety requirements placed on electronic products. Approval Reference Type: T11

Approval Logo	Certificates	Certification Body	Description
	VDE Approvals	VDE	VDE Certificate Number: 99759
c <b>FN</b> <sup>°</sup> us	UL Approvals	UL	UL File Number: E71572
	CQC Approvals	CQC	CCC Certificate Number: 2012010307564692

# T11-211

## Product standards

Product standards that are referenced

Organization	Design	Standard	Description
IEC	Designed according to	IEC 60934	Circuit-breakers for equipment (CBE)
(l)	Designed according to	UL 1077	Standard for Supplementary Protectors for Use in Electrical Equipment
CSA Group	Designed according to	CSA C22.2 No. 235	Supplementary Protectors
	Designed according to	GB 17701	Circuit-breaker for equipment

## **Application standards**

Application standards where the product can be used


Organization	Design	Standard	Description
IEC	Designed for applications acc.	IEC/UL 60950	IEC 60950-1 includes the basic requirements for the safety of information technologyequipment.


## Compliances


The product complies with following Guide Lines

	0		
Identification	Details	Initiator	Description
CE	CE declaration of conformity	SCHURTER AG	The CE marking declares that the product complies with the applicable requirements laid down in the harmonisation of Community legislation on its affixing in accordance with EU Regulation 765/2008.
ROHS	RoHS	SCHURTER AG	EU Directive RoHS 2011/65/EU
<b>50</b>	China RoHS	SCHURTER AG	The law SJ / T 11363-2006 (China RoHS) has been in force since 1 March 2007. It is similar to the EU directive RoHS.
REACH	REACH	SCHURTER AG	On 1 June 2007, Regulation (EC) No 1907/2006 on the Registration, Evaluation, Authorization and Restriction of Chemicals 1 (abbreviated as "REACH") entered into force.


## Dimension [mm]







T11-211 >7,5A



T11-211N

1) max. torque 0.6Nm

SW




## 

## Typical internal resistance

Rated Current [A]	Internal Resistance [ $\Omega$ ]
0.05	380.000
0.50	5.200
1.00	1.350
2.00	0.300
3.00	0.130
4.00	0.080
5.00	0.040
6.00	0.040
7.00	0.020
8.00	0.012
9.00	0.012
10.00	0.011
11.00	0.0095
12.00	0.0095
13.00	0.0085
14.00	0.0085
15.00	0.0075
16.00	0.0075

Time in Seconds

#### **Time-Current-Curves**



#### Effect of ambient temperature

The units are calibrated for an ambient temperature of +23°C. To determine the rated current for a lower or higher ambient temperature, use a correction factor (typical value) from the table below:

Correction factor
0.87
0.90
0.95
1.00
1.04
1.10
1.15
1.20

Example: Rated current = 5 A, Environmental temperature = 40 °C, --> Correction factor = 1.1, Resulting current = 5.5 A --> Fount to next higher rated current: 6 A

## Config. Code

## T11 - 1 2 3 A B - 1.23

The characters are placeholders for the correspondingly keys of selections from the key tables.

T11 - <b>1</b> 2 3 A B - 1.23 <b>= Mounting</b>		Terminal	Configuration
Mounting	Configuration		key
	key	Quick connect terminal 6.3x0.8mm	1
Threaded neck type 6 mm	2		
		T11 - 1 2 3 <b>A</b> B - 1.23 <b>= Shunt terminal</b>	
T11 - 1 <b>2</b> 3 A B - 1.23 <b>= Actuation Type</b>		Shunt terminal	Configuration key
Actuation Type	Configuration key	Shunt terminal	N
Reset type	1		
		T11 - 1 2 3 A <b>B</b> - 1.23 = Setting indication	
T11 - 1 2 <b>3</b> A B - 1.23 <b>= Terminal</b>			

Circuit Breakers

# T11-211

Setting indication	Configuration key
Setting indication	R

## T11 - 1 2 3 A B - 1.23 = Rated current

		2.077
Rated current	Configuration	3.0 A
	key	3.3 A
0.05 A	0.05	3.5 A
0.1 A	0.1	4.0 A
0.15 A	0.15	4.5 A
0.2 A	0.2	5.0 A
0.3 A	0.3	5.5 A
0.4 A	0.4	6.0
0.5 A	0.5	6.5 A
0.6 A	0.6	7.0 A
0.7 A	0.7	7.5 A
0.8 A	0.8	8.0 A
0.9 A	0.9	8.5 A
1.0	1	9.0 A
1.1 A	1.1	9.5 A
1.2 A	1.2	10.0 A
1.3 A	1.3	11.0 A
1.4 A	1.4	12.0 A
1.5 A	1.5	13.0 A
1.6 A	1.6	14.0 A
1.7 A	1.7	15.0 A
1.8 A	1.8	16.0 A
1.9 A	1.9	Other rated currents on request
2.0 A	2	Carlos ration outronto on request

Rated current	Configuration key
2.1 A	2.1
2.3 A	2.3
2.5 A	2.5
2.8 A	2.8
3.0 A	3
3.3 A	3.3
3.5 A	3.5
4.0 A	4
4.5 A	4.5
5.0 A	5
5.5 A	5.5
6.0	6
6.5 A	6.5
7.0 A	7
7.5 A	7.5
8.0 A	8
8.5 A	8.5
9.0 A	9
9.5 A	9.5
10.0 A	10
11.0 A	11
12.0 A	12
13.0 A	13
14.0 A	14
15.0 A	15
16.0 A	16

Other rated currents on request

## Variants

Rated current	Construction variants		Config. Code	Order Number	
	Shunt terminal	Setting indication	-		
1.0			T11-211-1	4400.0008	
3.0 A			T11-211-3	4400.0010	
0.8 A			T11-211-0.8	4400.0042	
12.0 A			T11-211-12	4400.0052	
1.5 A			T11-211-1.5	4400.0056	

Most Popular.

Availability for all products can be searched real-time:https://www.schurter.com/en/Stock-Check/ Stock-Check-SCHURTER

Packaging Unit 100 Pcs

# T11-211

## Accessories



Description

T-Line Accessories Accessories to T-Line