

Data sheet

261-314

**2-CONDUCTOR TERMINAL BLOCK LATERAL MARKING
SUITABLE FOR EEX I APPLICATIONS FOR ALUMINIUM RAIL 210-154 OR WITH
MOUNTING ADAPTER 209-120 FOR TS 35 SIDE-ENTRY**



Technical data

Package size 200 4*50 pieces.

| | |
|---------------------------------------|----------------------|
| Cross section from [mm ²] | 0.08 mm ² |
| Cross section to [mm ²] | 2.5 mm ² |
| Cross section from [AWG] | 28 AWG |
| Cross section to [AWG] | 14 AWG |
| Voltage UL | 300/600 V |
| Voltage CSA | 300/600 V |
| Current UL | 15/5 A |
| Current CSA | 20/5 A |
| Measured voltage EN | 500 V |
| Measured shock voltage | 6 kV |
| Pollution degree | 3 |
| Current intensity EN | 24 A |
| Weight | 2.3 g |
| Color | blue |
| Wiring type | Side-entry |
| No. of connection Points | 2 |
| No. of potentials | 1 |
| Height | 18 mm |
| Height | 0.709 in |
| Width | 6 mm |
| Width | 0.236 in |
| Depth | 28 mm |
| Depth | 1.103 in |

Data sheet

261-314

**2-CONDUCTOR TERMINAL BLOCK LATERAL MARKING
SUITABLE FOR EEX I APPLICATIONS FOR ALUMINIUM RAIL 210-154 OR WITH
MOUNTING ADAPTER 209-120 FOR TS 35 SIDE-ENTRY**

| | |
|-------------------|---------|
| Strip length from | 8 mm |
| Strip length to | 9 mm |
| Strip length | 0.33 in |

Data sheet

261-314

**2-CONDUCTOR TERMINAL BLOCK LATERAL MARKING
SUITABLE FOR EEX I APPLICATIONS FOR ALUMINIUM RAIL 210-154 OR WITH
MOUNTING ADAPTER 209-120 FOR TS 35 SIDE-ENTRY**

| Approval | Voltage | Current | Approval number | Notes |
|----------|---------|---------|-------------------|-------|
| BV | 500 | 24 | 07436/C0 | |
| CCA | 500 | 26 | DK96-00357 | |
| CSA | 300/600 | 20/5 | 18677-45 | |
| CSM | 500 | 26 | 017956 | |
| DEMKO | 500 | 24 | 120039/02 | |
| Dep.MaE | 300 | 27 | CS4590N | |
| DNV | 500 | 26 | E6998 | |
| GL | 500 | 24 | 17295-00HH | |
| KEMA | 500 | | 92.6446.02 | |
| KR | 500 | 24 | HMB05880-EL002 | |
| LR | 500 | 26 | 91/20242(E3) | |
| PRS | 500 | 26 | TE/1219/880590/98 | |
| RMR | 500 | 26 | 99.00007.250 | |
| RosTesT | 500 | 26 | B09523 | |
| SEMKO | 500 | | 9408057 | |
| UL | 300/600 | 15/5 | E45172 | |
| VDE | 500 | | 208ÜG,Bl.1 | |

Data sheet

261-314

**2-CONDUCTOR TERMINAL BLOCK LATERAL MARKING
SUITABLE FOR EEX I APPLICATIONS FOR ALUMINIUM RAIL 210-154 OR WITH
MOUNTING ADAPTER 209-120 FOR TS 35 SIDE-ENTRY**

Accessories

Item number

| | |
|---|-------------------------------|
| ALUMINIUM CARRIER RAIL 1000 MM / 3' 3 IN LONG | 210-154 |
| COMB TYPE JUMPER BAR INSULATED | 261-402 |
| END PLATE WITH SNAP-IN MOUNTING FOOT | 261-371 |
| END STOP FOR WSB QUICK MARKERS | 209-122 |
| Individual wire jumpers | individual jumper |
| MODULAR TEST PLUG ADAPTER MODULAR | 249-136 |
| MOUNTING CARRIER CAN BE USED AS END PLATE | 209-137 |
| MOUNTING FOOT FOR MOUNTING ON RELAY-MODULES | 209-120 |
| Open individual wire jumpers ends | individual jumper open end |
| OPERATING STICKER FOR SIDE-ENTRY PCB TERMINAL BLOCKS | 210-188/001-000 |
| OPERATING TOOL TO CONNECT JUMPERS | 209-132 |
| SCREWDRIVER 3.5 X 0.5 MM / 0.137 X 0.019IN | 210-257 |
| SCREWDRIVER Type 2, bar (3,5 x 0,5) mm | 210-120 |
| SCREWDRIVER WITH PARTIALLY INSULATED SHAFT Type 2, bar (3,5 x 0,5) mm | 210-620 |
| TEST ADAPTER-MODULE WITH FIXING FLANGES | 261-404 |
| TEST PLUG 2 MM / 0.079 IN WIDE | 210-136 |
| TEST PLUG 2.3 MM / 0.091 IN WIDE | 210-137 |