Circuit Breaker for Equipment thermal, Flange type, Manual ON/OFF, Screw terminals



See below:

Approvals and Compliances

Description

- Flange type
- Thermal circuit breaker
- 1-pole
- Manual ON/OFF type
- Bolts and nuts

Unique Selling Proposition

- Compact design
- Positively trip-free release
- Available with cover
- Different mounting possibilities

Applications

- Power supplies
- Uninterruptible power supply
- Power tools
- Household appliances

Weblinks

pdf datasheet, html-datasheet, General Product Information, Distributor-Stock-Check, Detailed request for product, Product News

Technical Data

Rated Voltage AC	240 V: 50/60 Hz
Rated Voltage DC	28 V
Rated current range AC	0.05 - 15/16 A, see approbations
Conditional short circuit ca-	IEC: Inc, PC1, AC 240 V: 1 kA
pacity	
Short circuit capacity Icn	at In < 7 A/240 VAC : 8 x In
	at In ≥ 7 A/240 VAC : 200 A
	AC/DC 28 V: 400 A
Degree of Protection	from front side IP 40 acc. to IEC 60529
Dielectric Strength	50 Hz: > 1.5 kV
	Impulse 1.2/50 μ s: > 2.5 kV
Insulation Resistance	$500\text{VDC} > 100\text{M}\Omega$
Endurance typical	2 x lr: 5000 switching cycles
Endurance minimum	Manual ON/OFF type
	AC: $2 \times Ir$, $\cos \varphi$ 0.6:
	DC: $2 \times Ir$, L/R = $2 - 3 \text{ ms}$: 5000 switching cycles

Overload	IEC: min. 40 trips	
	@ 6 x lr, cos φ 0.6	
	UL / CSA: min. 50 trips	
	@ 1.5 x lr, cos φ 0.75	
Allowable Operation Temp.	-5°C to 60°C	
Vibration Resistance	± 1.5 mm @ 10 - 60 Hz	
	acc. to IEC 60068-2-6, test Fc	
	10 G @ 60 - 500 Hz	
	acc. to IEC 60068-2-6, test Fc	
Shock Resistance	100 G / 6ms	
	acc. to IEC 60068-2-27, test Ea	
Tripping Type	Thermal	
Actuation Type	Manual ON/OFF	
Weight	ca. 10g	

Approvals and Compliances

Detailed information on product approvals, code requirements, usage instructions and detailed test conditions can be looked up in Details about Approvals

Approvals

The approval mark is used by the testing authorities to certify compliance with the safety requirements placed on electronic products. Approval Reference Type: T12

Approval Logo	Certificates	Certification Body	Description
Ď ^V E	VDE Approvals	VDE	VDE Certificate Number: 99673
c FL °us	UL Approvals	UL	UL File Number: E71572
(m)	CQC Approvals	CQC	CCC Certificate Number: 2012010307564275

Product standards

Product standards that are referenced

Organization	Design	Standard	Description
<u>IEC</u>	Designed according to	IEC 60934	Circuit-breakers for equipment (CBE)
(I)	Designed according to	UL 1077	Standard for Supplementary Protectors for Use in Electrical Equipment
CSA Group	Designed according to	CSA C22.2 No. 235	Supplementary Protectors
(III)	Designed according to	GB 17701	Circuit-breaker for equipment

Application standards

Application standards where the product can be used

Organization	Design	Standard	Description
<u>IEC</u>	Designed for applications acc.	IEC/UL 60950	IEC 60950-1 includes the basic requirements for the safety of information technology equipment. $\label{eq:continuous}$


Compliances


The product complies with following Guide Lines


Identification	Details	Initiator	Description
C€	CE declaration of conformity	SCHURTER AG	The CE marking declares that the product complies with the applicable requirements laid down in the harmonisation of Community legislation on its affixing in accordance with EU Regulation 765/2008.
RoHS	RoHS	SCHURTER AG	EU Directive RoHS 2011/65/EU
5	China RoHS	SCHURTER AG	The law SJ / T 11363-2006 (China RoHS) has been in force since 1 March 2007. It is similar to the EU directive RoHS.
REACH	REACH	SCHURTER AG	On 1 June 2007, Regulation (EC) No 1907/2006 on the Registration, Evaluation, Authorization and Restriction of Chemicals 1 (abbreviated as "REACH") entered into force.


Dimension [mm]

T12-112










Installation from rear


Installation from front

Diagrams


Tap 4,8 x 0,8 mm




Tap 4,8 x 0,8 mm



Tap 4,8 x 0,8 mm



Tap 4,8 x 0,8 mm



Approval		Main circuit			Auxiliary circuit		
		Rated current	Rated Voltage AC	Rated Voltage DC	Rated current	Rated Voltage AC	Rated Voltage DC
c FL °us	UL 1077 CSA C22.2 No. 235	0.0515 A	240 V	28 V	2 A 3 A	120 V -	- 28 V
(P)	CSA C22.2 No. 235	0.316 A	240 V	28 V	1 A	240 V	-
D VE	IEC 60934	0.0516 A	240 V	28 V	1 A	240 V	28 V
(3)	GB 17701	0.0516 A	240 V	28 V	1 A	240 V	28 V

Typical internal resistance

Rated Current [A]	Internal Resistance [Ω]
0.05	225.000
0.50	3.300
1.00	0.880
2.00	0.267
3.00	0.128
4.00	0.073
5.00	0.040
6.00	0.031
7.00	0.018
8.00	0.018
9.00	0.010
10.00	0.0087
11.00	0.0087
12.00	0.0087
13.00	0.0087
14.00	0.0070
15.00	0.0070
16.00	0.0055


Effect of ambient temperature

The units are calibrated for an ambient temperature of +23°C. To determine the rated current for a lower or higher ambient temperature, use a correction factor (typical value) from the table below:

Ambient Temperature [°C]	Correction factor
-5	0.87
0	0.90
10	0.95
23	1.00
30	1.05
40	1.12
50	1.20
60	1.30

Example: Rated current = 5 A, Environmental temperature = 50 °C, --> Correction factor = 1.2, Resulting current = 6.0 A

Time-Current-Curves



Config. Code

T12 - 1 2 3 A B C - 1.23

The characters are placeholders for the correspondingly keys of selections from the key tables.

T12 - 1 2 3 A B C - 1.23 = Mounting	
Mounting	Configuration key
Screwflange mounting	1
Threaded neck type with hexagonal- and knurled nut	2
T12 - 1 2 3 A B C - 1.23 = Actuation Type	
Actuation Type	Configuration key
Reset type	1
Manual ON/OFF (push/push)	2
Manual ON/OFF (push/push) T12 - 1 2 3 A B C - 1.23 = Terminal Terminal	2 Configuration key
T12 - 1 2 3 A B C - 1.23 = Terminal	Configuration
T12 - 1 2 3 A B C - 1.23 = Terminal Terminal	Configuration key 1
T12 - 1 2 3 A B C - 1.23 = Terminal Terminal Quick connect terminal 6.3x0.8mm	Configuration key
T12 - 12 3 A B C - 1.23 = Terminal Terminal Quick connect terminal 6.3x0.8mm Screw clamp terminals	Configuration key 1

	,
Shunt terminal	N
T12 - 1 2 3 A B C - 1.23 = Setting indication	
Setting indication	Configuration key
Setting indication	R
T12 - 1 2 3 A B C - 1.23 = Rated current	
- Hatou Garront	
Rated current	Configuration key
0.05 A	0.05
0.1 A	0.1
0.15 A	0.15
0.2 A	0.2
0.3 A	0.3
0.4 A	0.4
0.5 A	0.5
0.6 A	0.6
0.7 A	0.7
0.8 A	0.8
0.9 A	0.9
1.0	1

Other rated currents on request

Shunt terminal

1.1

Configuration key

Rated current	Configuration key	Rated current	Configuration key
1.2 A	1.2	5.0 A	5
1.3 A	1.3	5.5 A	5.5
1.4 A	1.4	6.0	6
1.5 A	1.5	6.5 A	6.5
1.6 A	1.6	7.0 A	7
1.7 A	1.7	7.5 A	7.5
1.8 A	1.8	8.0 A	8
1.9 A	1.9	8.5 A	8.5
2.0 A	2	9.0 A	9
2.1 A	2.1	9.5 A	9.5
2.3 A	2.3	10.0 A	10
2.5 A	2.5	11.0 A	11
2.8 A	2.8	12.0 A	12
3.0 A	3	13.0 A	13
3.3 A	3.3	14.0 A	14
3.5 A	3.5	15.0 A	15
4.0 A	4	16.0 A	16
4.5 A	4.5	Other rated currents on request	

Other rated currents on request

Packaging Unit 20 Pcs

Accessories

Description



T-Line Accessories Accessories to T-Line