Data sheet | Item number: 211-924

Nozzles; Length: 23 mm; For the use of 211-821; halogenated; Cable outer

diameter: 4.0 ... 7.0 mm; transparent

www.wago.com/211-924







Data

Technical data

Suitable	for wire diameter 4 7 mm
Properties	for one 211-821 marker
Marking device	Smart Printer (Thermal Transfer Printer)
Physical data	
Length	23 mm
Mechanical data	
Mounting type	Sliding
Material data	
Color	transparent
Material	PVC
Weight	0.8 g

 $\label{thm:condition} \textbf{Subject to changes. Please also observe the further product documentation!}$

WAGO Kontakttechnik GmbH & Co. KG Hansastr. 27 32423 Minden

Phone: +49571 887-0 | Fax: +49571 887-169 Email: info.de@wago.com | Web: www.wago.com Do you have any questions about our products? We are always happy to take your call at +49 (571) 887-44222.

Data sheet | Item number: 211-924

www.wago.com/211-924



Environmental requirements

Surrounding air temperature (storage)	5 40 °C
Surrounding air temperature (operation)	-15 70 °C
Relative humidity	40 80 %

Commercial data

Packaging type	bag
Country of origin	IT
GTIN	4055143381185
Customs tariff number	39269097900

Required accessories

Marking accessories



Item no.: 211-821 Marker card; for Smart Printer; for use in nozzles; Length: 23 mm; white

www.wago.com/211-821

Downloads

Environmental Product Compliance

Compliance Search

Environmental Product Compliance 211-924

URL

Download

Nozzles; Length: 23 mm; For the use of 211-821; halogenated; Cable outer diameter:

4.0 ... 7.0 mm; transparent

Installation Notes

Application

 $\label{thm:continuity} \textbf{Subject to changes. Please also observe the further product documentation!}$

WAGO Kontakttechnik GmbH & Co. KG Hansastr. 27

32423 Minden

Phone: +49571 887-0 | Fax: +49571 887-169 Email: info.de@wago.com | Web: www.wago.com Do you have any questions about our products? We are always happy to take your call at +49 (571) 887-44222.

Data sheet | Item number: 211-924


www.wago.com/211-924





Slide the marker into the marking sleeve receptacle. Replacing the marker is also possible after the conductor has been terminated.

Application



Compress the sleeve and slide it onto the conductor to be marked.

 $\label{thm:continuity} \textbf{Subject to changes. Please also observe the further product documentation!}$